

**FIRE INSPECTOR'S  
INTER-OFFICE CORRESPONDENCE**

**TO: Genaro Argenio, Planning Board Chairman**

**FROM: Francis Bedetti, Asst. Fire Inspector**

**SUBJECT: PB-06-33**  
**Jerry's Self Storage**  
**SBL: 29-1-92.2**

**DATE: December 6, 2006**

**Fire Prevention Reference Number: FPS-06-053**

A review of the above referenced site plan has been conducted and is acceptable with regards to 30' fire lanes.

- However, the proposed building of 48,000 sq. ft. is unacceptable with out a sprinkler system. Town Code 142-16 (A)